

MOBILE FOOD TRUCK COURTS GUIDELINES

Plumbing Plan Review

1. Each mobile food vehicle slot shall be provided with a sanitary waste receptor connected to the mobile food court sewage system and a grease laden waste receptor routed to a grease interceptor that is connected to the mobile food court sewage system. Grease waste receptors or interceptors shall never receive sanitary waste. (APC 1003.2)
 - a. Each waste receptor shall be a trapped four-inch riser pipe, surrounded at the inlet end by a concrete apron sloped to the drain and provided with a suitable hinged cover. (APC 1002.1)
 - b. A water outlet, equipped with approved backflow prevention devices, shall be connected to the mobile food court water supply system to permit periodic wash-down of the immediate adjacent area. (*Section 5B1 ADH Rules for RV Parks 2008*)
2. Individual water riser pipes shall be supplied for potable water and shall be located within the confined area of each mobile food unit space. (*Section 4B1 ADH Rules for RV Parks 2008*)
 - a. Individual water riser shall be equipped with approved backflow prevention devices. (*Section 4C1 ADH Rules for RV Parks 2008 & APC Section 608*)
 - b. The potable water supply riser pipe shall extend at least four inches vertically above ground elevation. (*Section 4B2 ADH Rules for RV Parks 2008*)
 - c. The water riser pipe shall be at least three-quarter (¾) inch in diameter. (*Section 4B2 ADH Rules for RV Parks 2008*)
 - d. The water outlet shall be capped when a mobile food unit does not occupy the lot. (*Section 4B2 ADH Rules for RV Parks 2008*)
 - e. Adequate provisions shall be made to prevent the freezing of service lines, valves and riser pipes. (*Section 4B3 ADH Rules for RV Parks 2008*)
 - f. Surface drainage shall be diverted away from the location of the riser pipe.
 - g. A shut-off valve below the frost line shall be provided near the water riser pipe on each mobile home space. Underground stop and waste valves shall not be installed on any water service line. (*Section 4B4 & 4B5, ADH Rules for RV Parks 2008*)
4. All water-piping fixtures shall be constructed and maintained in accordance with the current Arkansas State Plumbing Code. (*Section 4B6 ADH Rules for RV Parks 2008*)
5. Public Restrooms shall be provided per Arkansas Plumbing Code for occupancy type Assembly -2. (One water closet and lavatory for each gender per 150 persons and one service sink. A drinking fountain shall be provided unless drinking water is supplied free of charge.) (APC 403.2)