

ADDENDUM NO. 1

DATE: February 5, 2026

PROJECT: 8" Water Main Replacement – Highway 12 East (Harbor Dr to Bridge)

BIDS DUE: **Tuesday, February 10, 2026, 2:00 p.m.**
Utility Office, 601 South 2nd Street, Rogers, AR

OWNER: Rogers Water Utilities

ENGINEER: Engineering Services, Inc.
1207 South Old Missouri Road
Springdale, Arkansas 72764

MAKE THE FOLLOWING CHANGES IN THE PLANS & SPECIFICATIONS FOR THE CONTRACT.

Plans

Eliminate Sheet 7A from the plans. Sheet 7 will govern using ductile iron pipe.

Section 410 – Bid Form

The Basis of Bid (Article 5) has been modified to include more clarity. The quantities for the Base Bid will remain the same. However, the Deductive Alternate(s) have been modified. See attached revised Section 410 – Bid Form.

Clarifications

- Locking gaskets are required on the ductile iron pipe when it is located within steel encasement, **and** when the ground profile elevation is below 1132', which is the high water mark of the lake. We estimate that a total of 1,700 feet of ductile iron water main will require locking gaskets.
- 16" steel encasement is required on all road / driveway bores and wetland bores. The 16" steel encasement shall be a part of the 8" water main bore bid items (10 & 11).
- Bid Item 13 is "encasement" intended for areas where the water main may require additional protection by using 16" steel encasement via an open-cut trench.
- Bid Item 18 will include the actual weight of the fitting being installed. All other mega-lugs, bolts, connections, concrete backing, etc. will be considered incidental.
- Unit Prices used in the deductive alternate shall match unit prices on the base bid schedule.

END OF ADDENDUM NO. 1



Timothy J. Mays, P.E.
Engineering Services, Inc
Addendum No. 1 is a total of 8 sheets.