

ADDENDUM 1

Project Name: **Blossom Way Sewer Main Pauline Whitaker Dr. to Dixieland Rd.**

Release Date: October 9th, 2026

Bid Date: October 14th, 2026 (NO CHANGE)

Bidder Questions and Additional Information:

- **Epoxy Material:**

The following products are listed as approved for this project

Warren Environmental 301-14 epoxy

Quadex Structure Guard

OBIC

- **Rock Sounding Report:**

There was some discrepancies between the MCE report and the plan set from CTA due to a time difference between when the two were completed. Additional information included helps align the two together.

- **Bore Slopes:**

There will be a little variance in the bores that can be accounted for in the main line locations around the bores. The amount of variance is subject to location, but should stay around .25%.

Bidder shall acknowledge receipt of this addendum on the Page 410-1 of the Bid Form, and the outside of the sealed bid envelope.

ROGERS WATER UTILITIES



By: Aaron Short, PE
Senior Engineer